

UV340

Details

Category	Non-Storage Sprinklers
Class of Work	2012 - AS, Control Mode, Sidewall
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K (metric)	80
Coverage Type	Standard
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
K	5.6
Type	Horizontal Sidewall
Response	SR - Standard Response
Element	5 mm
NPT (in.)	1/2
Finish	Black Teflon, Chrome, Polyester, Brass
Temp. Rating (°F)	135, 155, 175, 200, 286
Temp. Rating (°C)	57, 68, 79, 93, 141

Company

GIACOMINI UNIVAL TESISAT ARMATÜRLERİ
SANAYI VE TICARET LTD. STI.,
Istanbul Anadolu Yakasi Organize Sanayi Bölgesi, Aydinli Mah.Mermerciler Cad. No: 10, Tuzla-Istanbul, Turkiye



Member of the FM Global Group

Listing Country Turkiye