



Sprinklers | Non-Storage Sprinklers | **Non-Storage Sprinklers**

UV321

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm





Details

Category	Non-Storage Sprinklers
Class of Work	2017 - AS, Control Mode, Pendent
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K (metric)	80
Coverage Type	Standard
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
K	5.6
Type	Pendent
Response	QR - Quick Response
Element	3 mm
NPT (in.)	1/2
Finish	Polyester, Chrome, Black Teflon, Brass
Temp. Rating (°F)	135, 155, 175, 200, 286
Temp. Rating (°C)	57, 68, 79, 93, 141
Listing Country	Turkiye

Company

GIACOMINI UNIVAL TESISAT
 ARMATÜRLERİ
 SANAYİ VE TİCARET LTD. STİ.,
 İstanbul Anadolu Yakası Organize
 Sanayi Bölgesi, Aydınli
 Mah.Mermerciler Cad. No: 10,
 Tuzla-Istanbul, Türkiye

Cookies help us improve your website experience.
 By using our website, you agree to our use of cookies.

Confirm