

HMER.EX15264 - Check Valves

Check Valves

WEFLO VALVE CO LTD

Intersection of Huadong Rd and Chunyang Rd
Qingdao National High-tech Industrial Development Zone
QINGDAO, SHANDONG 266111 China

EX15264

Model	Type	Valve Seat Facing	Nom Pipe Size, NPS	End Config	Rated Pressure, psig	Installation Position
F0311-300	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	F by F	300	H, V
F0322-300	Swing	Elastomeric	2, 2-1/2, 3, 4	T by G, T by T, T by F	300	H, V
F0322-300	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	G by G	300	H, V
F3322	Swing	Elastomeric	1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 6, 8	G	350	H, V
F3322B	Swing	Elastomeric	1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 6, 8	G	350	H, V
F0411-175	Swing	Elastomeric	4, 6, 8, 10, 12	W	175	V
F0411	Swing	Elastomeric	4, 6, 8, 10, 12	W	300	V
F0412-300	Wafer	Elastomeric	4, 6, 8	W	300	H, V
F1322	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	F by F	350	H, V

End Configuration:

F - Flanged

G - Grooved

T - Threaded

W - Wafer

Installation Position:

H - Horizontal installation

V - Vertical installation

Trademark and/or Tradename: **WEFLO®**, Weilong®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"