

UV0006

Details

Category	Non-Storage Sprinklers
Class of Work	2017 - AS, Control Mode, Pendent
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K	5.6
K (metric)	80
Type	Pendent
Response	QR - Quick Response
Element	3 mm
NPT (in.)	1/2
Finish	Chrome, Brass
Temp. Rating (°F)	135, 155, 175, 200, 286
Temp. Rating (°C)	57, 68, 79, 93, 141
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
Listing Country	Turkiye

Company

GIACOMINI UNIVAL TESISAT
ARMATÜRLERİ
SANAYİ VE TİCARET LTD. STİ.,
İstanbul Anadolu Yakası Organize
Sanayi Bölgesi, Aydınli
Mah.Mermerciler Cad. No: 10,
Tuzla-İstanbul, Türkiye