

Certificate of Quality System Approval

This is to certify that the product listed below conforms to the requirements of the

Pressure Equipment Directive 2014/68/EU

Annex III Module H

Certificate Number HPiVS-iP1057-071-Q-04-00

02-Aug-2022 Date of Issue

Manufacturer Giacomini Unival Tesisat Armatürleri Sanayi Ve Ticaret Limited Şirketi.

Köseler Mahallesi 10. Sk. No.4 Dilovası, Kocaeli, Turkey

Ball Valve: DN15-300, PN16 / PN25, TS 3148:2009, EN ISO

Date of Expiry

Surveillance due:

25-Apr-2025

25-Apr-2023

17292:2015

Butterfly Valve: DN15-400, PN16 / PN25, EN 593:2017 Strainer: DN15-400, PN16 / PN25, TS 11494:1994

Gate Valve: DN15-300, PN16 / PN25, TS EN 1171:2015 Description of Pressure Equipment Check Valve: DN15-300, PN16 / PN25, EN 1074-1:2000

Control Valve: DN50-300, PN16 / PN25

Balancing Valve: DN50-300, PN16, EN 13789:2010

Metal Hose: DN15-DN50, PN16 / PN25

Metal Expansion Joint: DN25 - DN250, PN16 / PN25, TS 10880:2016

Equipment Identification

CE dataplate on each Category I, II and III valve

Type of material Cast irons

ISO 9001:2015 Quality Management System Certificate no. GC-18-2147 issued by Other Certification

Goldcert

Standards Applied See description Report Reference HPiVS-iP1057-071-4

This Certificate is valid in any European Economic Area Member State.

This Report has been issued by HPi Verification Services (Ireland) Ltd. which is a body notified to the European Commission according to the provisions of the Pressure Equipment Directive (Notified Body number 2810).

This Report is issued following the assessment of the documentation and implementation of the Quality System in accordance with the provisions of the quoted Conformity Assessment Module of the above directive. The CE Mark may be affixed to the Pressure Equipment within the scope of approval as described above once the EU 'declaration of conformity' has been signed by the responsible person. The number '2810', being HPi Verification Services (Ireland) Ltd. Notified Body number should also be placed on the equipment dataplate.



Quality Director

Technical Director



www.hpivs.ie