GVI FIRE PUMP METERS - DIMENSIONAL DATA

MACHINED or CAST CARBON STEEL "WCB"

CONSTRUCTION & SPECIFICATIONS

MATERIALS: MACHINED 1018 / 1026 CARBON STEEL


POLYCARBONATE

or CAST CARBON STEEL "WCB"

VALVES: 1/4" BRASS BALL FLANGE OPT: 150# ANSI B 16.5 300# ANSI B 16.5


METER DATA CONSTRUCTION: ALUMINUM BODY OPERATION: DIAPHRAGM (BUNA CONVOLUTED) ACCURACY: + 2% FULL SCALE TEMPERATURE: 180°F / 80°C PRESSURE: 500 PSIG - 3450 KPA APPROX. WEIGHT: 3.75 LBS (1.7 KGS) 4" DIAL STANDARD - 6" DIAL AVAILABLE


MATERIALS AVAILIBLE: STAINLESS STEEL, BRASS, ALUMINUM, MONEL, VARIOUS PLASTICS, EPOXY COATED, AND MANY OTHERS. PLEASE CONSULT FACTORY.



ID TAG:







BUTT WELD / GROOVED

| - | |
|-----------|--|
| BUTT WELD | |

| O.T. | BUTT WELD & GROOVED | | 150 # FLANGED | | 300# FLANGED | |
|--------|---------------------|----------------|---------------|----------------|--------------|----------------|
| SIZE | "A" DIM | APPROX. WEIGHT | "A" DIM | APPROX. WEIGHT | "A" DIM | APPROX. WEIGHT |
| 1-1/4" | 4.875 | 2 lbs. | | | | |
| 2" | 5.000 | 3.5 lbs. | | | | |
| 2-1/2" | 4.000 | 5 lbs. | 9.250 | 21 lbs. | 10.000 | 28 lbs. |
| 3" | 4.000 | 6 lbs. | 9.375 | 30 lbs. | 10.250 | 36 lbs. |
| 3-1/2" | | | | | | |
| 4" | 5.375 | 10 lbs. | 11.375 | 40 lbs. | 12.125 | 60 lbs. |
| 5" | 6.000 | 20 lbs. | 13.000 | 58 lbs. | 13.750 | 84 lbs. |
| 6" | 7.000 | 22 lbs. | 14.000 | 70 lbs. | 14.750 | 106 lbs. |
| 8" | 7.250 | 31 lbs. | 15.250 | 93 lbs. | 16.000 | 181 lbs. |
| 10" | 8.000 | 45 lbs. | 16.000 | 149 lbs. | 17.250 | 227 lbs. |
| 12" | 12.000 | 78 lbs. | 21.000 | 238 lbs. | 22.250 | 358 lbs. |
| 14" | 14.000 | 85 lbs. | | - | | |
| 16" | 28 000 | 166 lbs | | | | |

OPERATING INSTRUCTIONS

- 1. CLOSE SYSTEM VALVE.
- 2. OPEN SYSTEM BY-PASS VALVE AND THROTTLE VALVE.
- 3. PURGE METER LOCATED ON VENTURI AS FOLLOWS:
 - OPEN SHUT-OFF VALVES & VENT VALVES.
 - WHEN A STEADY STREAM OF WATER IS PASSING THROUGH EACH PLASTIC HOSE, THE METER IS PURGED OF AIR.
 - CLOSE VENT VALVE AFTER PURGING.
- 4. START FIRE PUMP, READ METER IN GPM / LPM
- 5. REFER TO PUMP GPM / LPM REQUIREMENT AND ADJUST THROTTLE VALVE FOR THIS REQUIREMENT.
- AFTER TEST OPEN SYSTEM VALVE AND CLOSE SYSTEM BY-PASS AND THROTTLE VALVES.

